

 FEATURES
 X\$D ULTRA

 Frame Size
 143-449

 HP Range
 1-350

 Poles
 2,4,6 & 8

Voltages 230/460(230 max.100HP),460,575

Efficiency NEMA Premium IP55

Insulation Class H

Bearings Single Shielded ball or open roller

Vibration .04ips









GEGARD2000 Insulation System

Integral to motor life and reliability is a robust insulation system. The GEGARD system utilized in X\$D Ultra™ products gives a wide thermal margin between the insulation components and designed operation temperatures. All components except motor leads have been selected using Class H materials, while the motor temperature is kept below Class B temperature rise.

Six Star Bearing System ™

A key component in motor operation and longevity is the bearing system. The GE Six Star Bearing System has been designed to significantly reduce the potential for bearing failure. Vibration has been reduced to an industry leading 0.04 ips, reducing a leading cause of bearing failure. Regreasing consideration has been made easy with extended greasing provisions, which provides motor users the improved ability to regrease these motors when they are installed in the application.

Proven Reliability

A five year warranty comes standard with every IEEE 841 X\$D Ultra motor (60 months operational/66 months maximum from shipment). Rugged cast iron frame, conduit box, endshields & fan cover provide added protection not found in most motors in the market place.

| General Electric ULTRA X\$D Extra Severe Duty NEMA Premium 100HP - Double End Shaft #ITM507893 | | | | | | | |
|--|----------------------------------|--|--------------------------|------------------|----------------|--|--|
| | | | | Output = 100 | Phase = NEMA | NEMA Design = NA | Product Name = ULTRA X\$D Extra Severe Duty NEMA Premium |
| | | | | Synch RPM = 1800 | Frequency = 60 | DE E/S & Mtg Standard E/S & Foot Mounted | GE Type = Premium Efficiency - NEMA Design B, KS |
| Voltage = 460 | Shaft Orientation = Horiz. Shaft | C-face Dia. = NA | Ambient Temp. = 40 | | | | |
| Enclosure = TEFC | Hazardous Loc. = Non-Hazardous | Frame Material = | Insulation Class = H | | | | |
| IP & IC Code = IP55, IC411 | Class and Group = NA | Estimated Frame = 405 | Service Factor = 1.15 | | | | |
| Load Type = | Var. Freq. Speed Range = NA | DE Shaft Extension = DOUBLE END | Load Connection = Direct | | | | |
| Est. Weight =1560LB | | | | | | | |

Every General Electric motor is tested for the parameters listed below. The routine test consists of:

- a. Measurement of winding resistance.
- b. Measurement of no-load current and speed at rated voltage
- c. Measurement of locked rotor current at reduced voltage, single phase
- d. Measurement of no-load radial and axial vibration at rated voltage with the motor mounted on elastic pads.
- e. High-potential test per NEMA MG1, Part 3.

Note: On motors rated at other than 60 Hz, measurements may be taken at 60 Hz.